MASTER STREAM NOZZLE FOR MONITOR MODEL - VARSHA-40



TECHNICAL DATA

| NOZZLE FLOW RANGE | AS PER TABLE -1 | |
|-----------------------------|---|--|
| WATER INLET CONNECTION | Swivel Female 3" BSP | |
| MATERIAL OF CONSTRUCTION | Bronze, Stainless Steel, Hard Anodized Aluminium with Stainless Steel internals | |
| MAXIMUM SERVICE PRESSURE | 12 Bar (175 PSI) | |
| JET & FOG PATTERN | With Spinning teeth 120 degree angle | |
| WEIGHT (A pprox) | Bronze Nozzle - 9.2 Kg SS Nozzle - 8.8 Kg Aluminium Nozzle - 4.8 Kg | |
| APPROVAL | FM Approved | |

DESCRIPTION

VARSHA-40, is fixed gallonage master stream nozzle, designed for heavy-duty use on fixed monitors. The nozzle is factory set for required flow between 400 to 800 GPM. The flow can be changed in the field by replacing plunger or addition of spacer. The flow pattern easily changeable under flowing condition. Superior fog pattern with field changeable spinning teeth. Excellent for AFFF application when used with premixed water-foam solution.

The nozzle is available with three different materials, bronze, stainless steel and hard coat anodized alu minium, all with stainless steel internals.

The performance data shown in this catalogue is effective stream trajectory in stand still air condition.

The maximum overall reach of last water drop is approximately 3-5% more than the effective stream performance data given. The effective stream de creases by about 10% when used as foam nozzle with premixed water foam solution. The jet stream may get effected considerably with tail or head wind.

MAINTENANCE

The nozzle must be inspected regularly for possible damage or dirt around the moving parts. If any abnormal conditions are observed such as poor discharge, excessive wear, water leak, corrosion effect, damage etc., then nozzle must be taken out of service and repaired by qualified technician or replaced.

The debris trapped in the nozzle may effect the nozzle performance. To remove trapped debris, the water flow must be stopped and thereafter carefully unscrew and remove the nozzle deflector.



Clean the nozzle and reassemble. While re-assembling the nozzle or as a normal preventive maintenance, water proof lubricant must be used on seal and moving parts for smooth operation. The nozzle must be operated periodically under full flow straight stream and for fog pattern.

Under normal condition water must be flown through the nozzle periodically and dirt around exterior moving parts must be cleaned, allowing nozzle to operate properly.

The nozzle must be inspected prior to and after each use. Greasing the moving parts and 'O' ring is required periodically. Over a time the seals may need to be replaced.

The owner is responsible for maintenance of the nozzle in proper operating condition.

After use with foam, nozzle to be flushed with fresh water.

CAUTION




A trained personnel for fire fighting, with appropriate guidance & training must use the product to reduce the risk or injury. The nozzle must be fixed to the monitor carefully. The mismatched or damaged threads may cause leakage or uncouple the nozzle during operation.


Application of water or foam on an electric appliance can cause serious injury by electrocution, as water is a conductor of electricity.

The water supply to the nozzle must be gradual. Sudden surge of water supply must be avoided. The monitor mounting must be supported properly to support the nozzle reaction force.

MASTER STREAM NOZZLE FOR MONITOR MODEL - VARSHA-40







PERFORMANCE DATA

TABLE - I

| 77.02.2.1 | | | |
|---------------|-----------------|------------------|---------------------|
| SET FLOW RATE | PRESSURE | ACTUAL FLOW RATE | STRAIGHT STREAM |
| LPM (GPM) | KG/CM.SQ. (PSI) | LPM (GPM) | RANGE METERS (FEET) |
| 1500 (400) | 5.6 (80) | 1342 (354) | 54 (177) |
| | 7.0 (100) | 1500 (396) | 58 (190) |
| | 8.4 (120) | 1643 (434) | 60 (196) |
| 1900 (500) | 5.6 (80) | 1700 (450) | 57 (187) |
| | 7.0 (100) | 1900 (502) | 61 (200) |
| | 8.4 (120) | 2080 (550) | 63 (207) |
| 2270 (600) | 5.6 (80) | 2030 (536) | 58 (190) |
| | 7.0 (100) | 2270 (600) | 62 (203) |
| | 8.4 (120) | 2485 (656) | 64 (210) |
| 2650 (700) | 5.6 (80) | 2370 (626) | 61 (200) |
| | 7.0 (100) | 2650 (700) | 63 (207) |
| | 8.4 (120) | 2903 (767) | 64 (210) |
| 3030 (800) | 5.6 (80) | 2710 (716) | 63 (207) |
| | 7.0 (100) | 3030 (800) | 65 (213) |
| | 8.4 (120) | 3319 (876) | 66 (216) |

PERFORMANCE DATA FOR WATER STREAM RANGE ARE BASED AT 30 DEG. NOZZLE ELEVATION IN STILL AIR CONDITION AND WITH HD MONITOR. WHEN USED WITH PREMIXED WATER FOAM SOLUTION THE FOAM REACH WILL DECREASE BY APPROXIMATELY 10% TO 15%. THE ABOVE NOZZLE DATA IS WITH HD MONITOR INLET PRESSURE.

LIMITED WARRANTY

HDFIREPROTECTPVT.ITD.herebyreferredtoasHDFIREwarrantstotheoriginalpurchaserofthefireprotectionproductsmanufacturedbyHDFIREandtoanyotherperson towhom such equipment is transferred, that such products will be free from defect in material and workmanship under normal use and care, for two (2) years from the date of shipment by HDFIRE. Products or Components supplied or used by HDFIRE, but manufactured by others, are warranted only to the extent of the manufacturer's warranty. No warranty is given for product or components which have been subject to misuse, improper installation, corrosion, unauthorized repair, alteration or un-maintained. HD FIRE shall not be responsible for system design errors or improper installation or inaccurate or incomplete information supplied by buyer or buyer's representatives. HDFIRE will repair or replace defective material free of charge, which is returned to our factory, transportation charge prepaid, provided after our inspection the material is found to have been defective at the time of initial shipment from our works. HDFIRE shall not be liable for any including damages for injury toperson, damages toproperty and penalties resulting from any products and components manufactured by HD FIRE. HD FIRE shall not be liable for any damages or labour charges or expense in making repair or adjustment to the product. HD FIRE shall not be liable for any damages or charges sustained in the adaptation or use of fits engineering data & services. In no event shall HD Fire's product liability exceed an amount equal to the sale price. The foregoing warranty is exclusive and in lieu of all other warranties and representations are hereby cancelled.

NOTICE:

The equipment presented in this bulletin is to be installed in accordance with the latest publication standards of NFPA or other similar organisations and also with the provision of government codes or ordinances wherever applicable.

The information provided by us is to the best of our knowledge and belief, and consist of general guidelines only. Site handling and installation control is not in our scope. Hence we give no guarantee for result and take no liability for damages, loss or penalties whatsoever, resulting from our suggestion, information, recommendation or damages due to our product.

Product development is a continuous programme of HD FIRE PROTECT PVT. LTD. and hence the right to modify any specification without prior notice is reserved with the company.

Celéfono: (511) 639-0193

Celular: 973 293 091 | 914 407 708

www.acisprocess.com

